



DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NV-5180AL0188
Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas and water supply <i>Produkte der Gas- und Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
Distributor <i>Vertreiber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
Product Category <i>Produktart</i>	Greasing and sealing materials: Protection tape against corrosion (5180)
Product description <i>Produktbezeichnung</i>	Single tape corrosion prevention coating with primer
Model <i>Modell</i>	DENSOLEN®-AS40 Plus (C 50)
Test reports <i>Prüfberichte</i>	Type testing: 15/002/5180/1 from 15.07.2015 (EBI) Laboratory control test: 21-01023-KP05- from 04.07.2025 (EBI)
Test basis <i>Prüfgrundlagen</i>	DIN EN 12068 (01.03.1999) DIN 30672-1 (01.05.2019)

Date of Expiry / File No. 31.08.2030 / 25-0282-GNV
Ablaufdatum / Aktenzeichen

70028-04-A-DE

15.08.2025 Cat A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

1A-20-71



DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvbw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
DENSOLEN®-AS40 Plus (C 50)	Stress class: C Permanent operating temperature: +50 °C Designation according to standard: Umhüllung EN 12068-C 50 bzw. DIN 30672-1-C 50	

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

handling: cold handle protection tape against corrosion with 4 layers on primer

